MINUTES

Regular Meeting Laguna Madre Water District Board of Directors Wednesday, April 22, 2020 5:30 PM – 6:12 PM

Board Room

| 1 | QUORUM PRESENT: Chairman, Scott Friedman Vice-Chairman, Herb Houston Secretary, Alex Avalos Director, Jason Starkey - Virtual Meeting with Zoom Director, Adam Lalonde - Virtual Meeting with Zoom ADMINISTRATIVE STAFF: General Manager, Carlos J. Galvan, Jr. Director of Operations, Robert Gomez District Engineer, Charles Ortiz Purchasing Agent, Enrique Samaniego - Virtual Meeting with Zoom Director of Finance, Eddie Salazar Attorney, Brian Hansen - Virtual Meeting with Zoom | |
|---|---|----|
| 2 | INVOCATION AND PLEDGE OF ALLEGIANCE | |
| | The meeting began with the Pledge of Allegiance, and C. Ortiz said the Invocation. | |
| 3 | INVITATION TO THE AUDIENCE FOR PUBLIC COMMENTS | |
| | COMMENTS: | |
| | Alicia and Victor Baldovinos with Grant Access (virtual meeting)reported: | |
| | o Earth Day information posted on social media | |
| | o Information on Water Conservation posted on social media relating to Earth Day | |
| | o Grant Access Media Affairs Consultants six months on the job in working with the District | |
| | R. Gomez noted, thanking Grant Access for preparing the letter and doing a good job concerning the problems with the sewer lines (with flushing wipes), arrangments in the works to mail the message (copies in English and Spanish) to District Customers. | |
| | ✓ Suggestion: include a picture with the letter | |
| | For the next, regularly scheduled meeting reporting on the new Pre-treatment department's work on cleaning out the lift stations with photos of how clean it looks after cleaning | |
| 4 | CONSIDER AND DISCUSS FOR POSSIBLE APPROVAL THE MINUTES OF THE REGULAR | |
| | MEETING FROM APRIL 8TH, 2020. (C. GALVAN) | |
| | DISCUSSION: | 47 |

| | The Board approved the Regular Meeting Minutes as presented | |
|---|--|-----------|
| | Moved by H. HOUSTON, seconded by A. LALONDE. | MOTION |
| | Move to approve. | CARRIED |
| | | |
| 5 | GENERAL MANAGER'S | |
| | REPORT: | |
| | COVID-19 UPDATES — | |
| | o Human Resources updated essential traveler letters extending the date to May 4, 2020 | |
| | Updates frequently reported by the County and City related to COVID-19 Shelter in | GENERAL |
| | Place | MANAGER'S |
| | SCHEDULE POSSIBLE WORKSHOP CONCERNING FINANCIAL REPORTS FOR CUSTOMER DEFERRED ASSISTANCE — | REPORT |
| | o Recommendation for scheduling a Workshop, preferably the second meeting in May to ensure all expenditures are complete and information is available for the Workshop | |
| ļ | o Possibly a 5 PM Regular Meeting instead of a Workshop | |
| | Establishing the Deferred Assistance Program should perhaps follow the guidelines from the Public Utilities Commission (PUC). | |
| | ✓ The Board agreed to schedule as a regular agenda item for May 27, 2020 | |
| 6 | DISCUSS AND APPROVE A RESOLUTION EXPRESSING OFFICIAL INTENT TO REIMBURSE ENGINEERING COSTS RELATED TO IMPROVING RENOVATING AND EQUIPPING WATER TREATMENT PLANT 1 FROM TAX-EXEMPT OBLIGATIONS TO BE ISSUED BY THE LAGUNA MADRE WATER DISTRICT AND OTHER MATTERS RELATED THERETO (RESOLUTION NO. 179-04-2020). (C. GALVAN) | |
| | DISCUSSION: | |
| | Recommendation from Bond Counsel | MOTION |
| | Reimbursement Amount - up to \$200,000 | CARRIED |
| | The Board agreed to approve the Resolution by a rollcall vote: | |
| | o NOES: None o AYES: | |
| | A. AVALOS J. STARKEY | |
| | A. LALONDEH. HOUSTON | |
| | • S. FRIEDMAN | |
| | Moved by A. AVALOS, seconded by J. STARKEY. | |
| | Move to approve | |

| The Consider and Discuss For Possible APPROVAL OF EXTENDING THE CONTINGENCY SCHEDULE IN CONJUNCTION WITH THE MANDATED CAMERON COUNTY ORDERS CONCERNING COVID19. (c. GALVAN) DISCUSSION: • Contingency Schedule Extension until on or before May 13, 2020 • The Board agreed to approve extending the Contingency Schedule Moved by H. HOUSTON, seconded by A. LALONDE. Move to approve Moved by H. HOUSTON, seconded by A. LALONDE. Move to approve **REPORT: • **POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY - • Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media • Information from current meter and previous meter testing's show 100% accuracy • In both cases, the issues occurred at the same time frame • Possible causes: bad commode (bad flapper) or water left running • Meter Test fee of \$52.50 waived • Meter is going to be monitored as much as possible and will work with Customer as much as possible on the media **DISTRICT ENGINEER'S REPORT** **REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT - • Advertised April 16, 2020, and are due on May 1, at 2 PM • The format in place with the reimbursement engineering costs • Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020. ② 9 AM • Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020. ② 9 AM • Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020. ② 9 AM • Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020. ② 10 AM • Professional Services Committee Meeting for Informational Plant Tenewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Lagu | | | |
|---|---|---|-------------|
| The Board agreed to approve extending the Contingency Schedule Moved by H. HOUSTON, seconded by A, LALONDE. Move to approve 8 DIRECTOR OF OPERATION'S REPORT REPORT: • POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY • Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media • Information from current meter and previous meter testing's show 100% accuracy • In both cases, the issues occurred at the same time frame • Possible causes: bad commode (bad flapper) or water left running • Meter Test fee of \$25.00 waived • Meter Test fee of \$25.00 waived • Meter is going to be monitored as much as possible and will work with Customer as much as possible and as possi | 7 | SCHEDULE IN CONJUNCTION WITH THE MANDATED CAMERON COUNTY ORDERS CONCERNING COVID19. (c. GALVAN) DISCUSSION: | |
| Moved by H. HOUSTON, seconded by A. LALONDE. Move to approve 8 DIRECTOR OF OPERATION'S REPORT ● REPORT: • POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY - • Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media • Information from current meter and previous meter testing's show 100% accuracy • In both cases, the issues occurred at the same time frame • Possible causes: bad commode (bad flapper) or water left running • Meter Test fee of \$25.00 waived • Meter is going to be monitored as much as possible and will work with Customer as much as possible 9 DISTRICT ENGINEER'S REPORT REPORT: • REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — • Advertised April 16, 2020, and are due on May 1, at 2 PM • The District provided a copy of RPQ's to all interested firms • So far, four firms interested • The format in place with the reimbursement engineering costs • Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM • Professional Services Committee Members, A. Avalos, and I. Starkey agreed to the meeting and will receive review documents on May 5, 2020 • WASTEWATER DISCHARGE PERMIT RENEWAL, — ANDY 80WIE WASTEWATER TREATMENT PLANT • For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. • We received the draft permits for review and approval for the Andy Bowie and Port | | | |
| Move to approve B DIRECTOR OF OPERATION'S REPORT REPORT: POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY — Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media Information from current meter and previous meter testing's show 100% accuracy In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible DISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Meembers, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020. WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (flour sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | | |
| B DIRECTOR OF OPERATION'S REPORT POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY - Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media Information from current meter and previous meter testing's show 100% accuracy In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible DISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFO's to all interested firms The format in place with the reimbursement engineering costs The format in place with the reimbursement engineering costs REPORT POSSIBLE REPORT DISTRICT ENGINEER'S REPORT POSSIBLE REPORT REPORT DISTRICT ENGINEER'S REPORT OF the Wastewater Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for | | Moved by H. HOUSTON, seconded by A. LALONDE. | |
| REPORT: POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY — Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threaters to go to the media Information from current meter and previous meter testing's show 100% accuracy In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible POSTRICT ENGINEER'S REPORT REPORT: REPORT: REPORT: REPORT: REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | Move to approve | |
| POTENTIAL COMPLAINT TO NEWS MEDIA BY A WATER DISTRICT CUSTOMER CONCERNING METER DISCREPANCY Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media Information from current meter and previous meter testing's show 100% accuracy In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter fest fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible POINTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | 8 | DIRECTOR OF OPERATION'S REPORT | |
| DIRECTOR Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media Information from current meter and previous meter testing's show 100% accuracy In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible PISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs REPORT REPORT Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020. WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | : | REPORT: | |
| o Notice from Customer given on April 15, Customer believes the meter is not registering correctly. Customer threatens to go to the media o Information from current meter and previous meter testing's show 100% accuracy o In both cases, the issues occurred at the same time frame o Possible causes: bad commode (bad flapper) or water left running o Meter Test fee of \$25.00 waived o Meter is going to be monitored as much as possible and will work with Customer as much as possible 9 DISTRICT ENGINEER'S REPORT REPORT: • REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— o Advertised April 16, 2020, and are due on May 1, at 2 PM o The District provided a copy of RFQ's to all interested firms o So far, four firms interested o The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM o Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 • WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT o For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. o We received the draft permits for review and approval for the Andy Bowie and Port | | | DIRECTOR |
| o In both cases, the issues occurred at the same time frame Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible DISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs REPORT REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms The format in place with the reimbursement engineering costs REPORT Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | | |
| Possible causes: bad commode (bad flapper) or water left running Meter Test fee of \$25.00 waived Meter is going to be monitored as much as possible and will work with Customer as much as possible Meter is going to be monitored as much as possible and will work with Customer as much as possible DISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs REPORT REPORT Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | o Information from current meter and previous meter testing's show 100% accuracy | OPERATION'S |
| o Meter Test fee of \$25.00 waived o Meter is going to be monitored as much as possible and will work with Customer as much as possible 9 DISTRICT ENGINEER'S REPORT REPORT: • REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— o Advertised April 16, 2020, and are due on May 1, at 2 PM o The District provided a copy of RFQ's to all interested firms o So far, four firms interested o The format in place with the reimbursement engineering costs o Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM o Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 • WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT o For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. o We received the draft permits for review and approval for the Andy Bowie and Port | | o In both cases, the issues occurred at the same time frame | REPORT |
| O Meter is going to be monitored as much as possible and will work with Customer as much as possible DISTRICT ENGINEER'S REPORT REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT— Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | o Possible causes: bad commode (bad flapper) or water left running | |
| ### DISTRICT ENGINEER'S REPORT REPORT: ***REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — O Advertised April 16, 2020, and are due on May 1, at 2 PM O The District provided a copy of RFQ's to all interested firms O So far, four firms interested The format in place with the reimbursement engineering costs O Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM O Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 **WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT O For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. O We received the draft permits for review and approval for the Andy Bowie and Port | | o Meter Test fee of \$25.00 waived | |
| REPORT: REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | | |
| REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT – Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | 9 | DISTRICT ENGINEER'S REPORT | |
| Advertised April 16, 2020, and are due on May 1, at 2 PM The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | REPORT: | |
| The District provided a copy of RFQ's to all interested firms So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | REQUEST FOR QUALIFICATIONS FOR WATER PLANT 1 CLARIFIER REPLACEMENT — | |
| So far, four firms interested The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | o Advertised April 16, 2020, and are due on May 1, at 2 PM | |
| The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | o The District provided a copy of RFQ's to all interested firms | DISTRICT |
| The format in place with the reimbursement engineering costs Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | o So far, four firms interested | ENGINEER'S |
| Requesting a Professional Services Committee Meeting to review proposals and recommendations. Meeting for possibly for May 5, 2020, @ 9 AM Professional Services Committee Members, A. Avalos, and J. Starkey agreed to the meeting and will receive review documents on May 5, 2020 WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | The format in place with the reimbursement engineering costs | |
| MASTEWATER DISCHARGE PERMIT RENEWAL — ANDY BOWIE WASTEWATER TREATMENT PLANT For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | | ner on i |
| For the Wastewater Treatment Plant (four sewer plants), all four permit renewals submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. We received the draft permits for review and approval for the Andy Bowie and Port | | · · · · · · · · · · · · · · · · · · · | |
| submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla Blanca. O We received the draft permits for review and approval for the Andy Bowie and Port | | WASTEWATER DISCHARGE PERMIT RENEWAL – ANDY BOWIE WASTEWATER TREATMENT PLANT | |
| | | submitted; they have been declared administratively complete. The next step is to get the technical review completed; the results are still pending for Laguna Vista and Isla | |
| | | | |

| 13 | ADJOURNMENT There being no further business the CHAIRMAN adjourned the meeting 6:12 PM | MEETING ADJOURNED @ 6:12 PM |
|----|---|-----------------------------------|
| | No questions or comments Expenditures acknowledged by H. HOUSTON and J. STARKEY. | OF EXPENDITURES |
| 12 | CONSIDER AND REVIEW EXPENDITURES FROM APRIL 1, 2020 – APRIL 15, 2020. (C. GALVAN) ♦ DISCUSSION: | ACKNOWLEDGMENT |
| 11 | CONSIDER AND DISCUSS FOR POSSIBLE APPROVAL ENCODER REGISTER FOR FIRE METERS PART OF THE METER REPLACEMENT PROGRAM. (E. SAMANIEGO) DISCUSSION: • E. Samaniego recommended No Action; the Encoders included with Muller's Agreement | NO ACTION |
| | Moved by J. STARKEY, seconded by A. AVALOS. Move to approve | |
| | Pre-Treatment Manager will oversee and monitor the grease traps for the Restaurants so that grease won't go into the sewer lines that cause a lot of sewer backups Pre-Treatment Manager will meet with all Restaurant Managers Discussion ensued regarding the training for the new Pre-Treatment Manager Comment: The District needs to review the different cities that they have for grease traps and have it placed on their ordinance as a requirement. The towns need to mandate to enforce compliance, not just the District. It should be the Districts and each Community's Policy, all the same. Discussion ensued. | MOTION CARRIED |
| 10 | CONSIDER AND DISCUSS FOR POSSIBLE APPROVAL BUDGET AMENDMENT TO RESTORE LIFT STATION DEPARTMENT 2 TO PRE-TREATMENT/LIFT STATION DEPARTMENT (E. SALAZAR) DISCUSSION: Reorganization for the hiring of the new Pre-Treatment Manager | - |
| | Andy Bowie, with its discharging into the Birding Center area, got a copper restriction on that permit renewal, so it's going to require three years to determine how to address that copper limit. It's set as a new discharge limitation Question: Is that an additional cost for the District, and do we have to meet that? Response: Yes, because of our stream analysis Question: How much additional money? Response: It's unknown at this stage, quarterly reports needed to identify the source to know what we can do to meet that restriction. Discussion ensued regarding the permit costs. | |

SCOTT FRIEDMAN, CHAIRMAN

ALEX AVALOS, SECRETARY



MINUTES APPROVED THIS 13TH DAY OF MAY 2020.